Alloway
Your Resource for Defensible Data

CERTIFICATE OF ANALYSIS
Reported by Alloway - Marion
Chain of Custody attached

McComb WTP
Attn: Tom Shumaker
210 E Main St
P O Box 340
McComb, OH 45858

Project Name: **McComb WTP**

Sample ID: **DS202**
Lab Sample # **M15-26959-02**

Lab Project # M15-26959
Received: 11/17/2015
Reported: 12/2/2015
Date/Time Sampled: 11/11/2015 15:35
Sampled By: TS
Sampled Matrix: Drinking Water
Containers: 4
Collection Method: Grab

Analyte	Results	Units	PQL	Preparation Method	Analytical Method	Analyst	Extraction Date	Analysis Date/Time
Bromoform	<0.5	ug/L	0.5		EPA 524.2 Rev. 4.1	MRH		11/22/2015
Bromodichloromethane	2.6	ug/L	0.5		EPA 524.2 Rev. 4.1	MRH		11/22/2015
Chloroform	51.0	ug/L	0.5		EPA 524.2 Rev. 4.1	MRH		11/22/2015
Dibromochloromethane	0.6	ug/L	0.5		EPA 524.2 Rev. 4.1	MRH		11/22/2015
Trihalomethane (Total)	54.2	ug/L	2.0		EPA 524.2 Rev. 4.1	MRH		11/22/2015
(Surrogate) 1,2-Dichlorobenzene-d4 70 - 130	101.5	%			EPA 524.2 Rev. 4.1	MRH		11/22/2015
(Surrogate) Bromofluorobenzene 70 - 130	106.8	%			EPA 524.2 Rev. 4.1	MRH		11/22/2015
Dibromoacetic acid	<1.0	ug/L	1.0		EPA 552.2 Rev. 1.0	RDK	11/20/2015	11/25/2015
Dichloroacetic acid	34.7	ug/L	1.0		EPA 552.2 Rev. 1.0	RDK	11/20/2015	11/25/2015
Monobromoacetic acid	<1.0	ug/L	1.0		EPA 552.2 Rev. 1.0	RDK	11/20/2015	11/25/2015
Monochloroacetic acid	<2.0	ug/L	2.0		EPA 552.2 Rev. 1.0	RDK	11/20/2015	11/25/2015
Trichloroacetic acid	20.4	ug/L	1.0		EPA 552.2 Rev. 1.0	RDK	11/20/2015	11/25/2015
Haloacetic acids (Total)	55.1	ug/L	6.0		EPA 552.2 Rev. 1.0	RDK	11/20/2015	11/25/2015
(Surrogate) 2-Bromobutanoic acid 70 - 130	102.2	%			EPA 552.2 Rev. 1.0	RDK	11/20/2015	11/25/2015

High School
80.0 ug/L MAX

Analysis Certified By: Erin L. Hohman

Erin L. Hohman

This report shall not be reproduced, except in its entirety, without the written approval of the laboratory.
The results presented on this Certificate of Analysis only reflect those parameters that were requested by the client on the chain of custody or other documentation received with the sample(s). The analytical results relate only to the items tested. Analytical results are based on dry-weights for solid samples, unless otherwise specified.

Total
Max
Min
Avg

1101 N. Cole Street - Lima, Ohio 45805
419.223.1362 - Fax 419.227.3792
800.436.1243

508 Bissman Ct. - Mansfield, Ohio 44903
419.525.1644 - Fax 419.524.5575
800.635.3222

1776 Marion-Waldo Rd. - Marion, Ohio 4330
740.389.5991 - Fax 740.389.1481
800.873.2835

www.alloway.com